RECEIVED-WATER SUPPLY

2021 MAY 24 PM 2:53

MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION

Consumer Confidence Report (CCR)

Town of Woodville

Public Water System Name

0790007

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION *(Check all boxes that apply.)*

NOTICE OF DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
☑ Advertisement in local paper *(Attach copy of advertisement)*	5/20/2021
☐ On water bills *(Attach copy of bill)*	
☐ Email message *(Email the message to the address below)*	
☐ Other _____	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	**DATE ISSUED**
☐ Distributed via U. S. Postal Mail	
☐ Distributed via E-Mail as a URL *(Provide Direct URL):* _____	
☐ Distributed via E-Mail as an attachment	
☐ Distributed via E-Mail as text within the body of email message	
☐ Published in local newspaper (attach copy of published CCR or proof of publication)	
☐ Posted in public places (attach list of locations)	
☐ Posted online at the following address *(Provide Direct URL):* _____	

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Name	Title	Date
Keshia J Fox	Mayor	5/24/2021

SUBMISSION OPTIONS *(Select one method ONLY)*

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576-7800 (NOT PREFERRED)

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

2020 Annual Drinking Water Quality Report
Town of Woodville
PWS#: 0790007
May 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Miocene Series Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Woodville have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Bryant B. Longs at 601.660.3588. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the regular scheduled meetings held on the first Tuesday of each month 5:00 PM at Municipal Building located at 131 Courthouse Street.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2018*	.0752	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2018/20	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018*	.102	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

17. Lead	N	2018/20	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019*	32000	No Range	PPB	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products

81. HAA5	N	2020	3	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	3.15	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	1.8	.9– 2.4	mg/l	0	MDRL = 4	Water additive used to control microbes

Unregulated Contaminants

Manganese	N	2020	84	57 - 84	UG/L			Naturally-occurring element; commercially available in combination with other elements and minerals; used in steel production, fertilizer, batteries and fireworks; drinking water and wastewater treatment chemicals; essential nutrient
HAA5	N	2020	1.36	1.28 – 1.36	UG/L			
HAA6BR	N	2020	.87	No Range	UG/L			
HAA9	N	2020	2.23	1.28 – 2.23	UG/L			

** Most recent sample. No sample required for 2020.*

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

We at Town of Woodville around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

This report will not be delivered to each customer however copies are available at our office.

PROOF OF PUBLICATION

THE STATE OF MISSISSIPPI,
Wilkinson County

2020 Annual Drinking Water Quality Report
Town of Woodville
PWS#: 0790007
May 2021

o you this year's Annual Quality Water Report. This report is designed to inform you about the quality water [illegible] and very day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We [illegible] you to make to continually improve the water treatment process and protect our water resources. We are [illegible] to water. Our water source is from wells drawing from the Miocene Series Aquifer.

ent has been completed for our public water system to determine the overall susceptibility of its drinking water l sources of contamination. A report containing detailed information on how the susceptibility determinations were o our public water system and is available for viewing upon request. The wells for the Town of Woodville have bility rankings to contamination.

about this report or concerning your water utility, please contact Bryant B. Longs at 601.[illegible] We want our rmed about their water utility. If you want to learn more, please attend the regular scheduled meetings held on the 5:00 PM at Municipal Building located at 131 Courthouse Street.

taminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water ed during the period of January 1st to December 31st, 2020. In cases where monitoring wasn't required in 2020, the t results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in terials and can pick up substances or contaminants from the presence of animals or from human activity; microbial ses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, aminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, wwater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a griculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and which are by-products of industrial processes and petroleum production, and can also come from gas stations and contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In er is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by inking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of portant to remember that the presence of these contaminants does not necessarily indicate that the water poses a [illegible]

any terms and abbreviations you might not be familiar with. To help you better understand these terms we've lone:

ation of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must [illegible]

A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

l (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking [illegible] MCLGs as feasible using the best available treatment technology.

l Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is [illegible] CLGs allow for a margin of safety.

TEST RESULTS

Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
inants						
2018*	.0752	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
2018/20	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
2018*	.102	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
2018/20	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
2019*	32000	No Range	PPB	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents
roducts						
2020	3	No Range	ppb	0	60	By-Product of drinking water disinfection.
2016*	3.15	No Range	ppb	0	80	By-product of drinking water chlorination.
2020	1.0	.9 – 2.4	mg/l	0	MDRL = 4	Water additive used to control microbes
aminants						
2020	84	67 - 84	UG/L			[illegible]
2020	1.36	1.28 – 1.36	UG/L			
2020	.67	No Range	UG/L			
2020	2.23	1.28 – 2.23	UG/L			

le required for 2020

ur system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and learned through our monitoring and testing that some contaminants have been detected however the EPA has SAFE at these levels.

ur drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of ater meets health standards. We did complete the monitoring requirements for bacteriological sampling that n an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing compliance period.

ad can cause serious health problems, especially for pregnant women and young children. Lead in drinking water components associated with service lines and home plumbing. Our water system is responsible for providing t cannot control the variety of materials used in plumbing components. When your water has been sitting for e the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking d about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing can take to minimize exposure is available from the Safe Drinking Water Hotline [illegible]

WOODVILLE, MISS., Thursday, May [illegible]

PERSONALLY appeared before me the undersigned Notary P[illegible] ANDY J. LEWIS, Editor of THE WOODVILLE REPUBLICAN, who bein[g] sworn says on oath that the publication, a copy of which is hereto att[ached] was published in THE WOODVILLE REPUBLICAN, a newspaper publis[hed in] said County and State, for 1 successive weeks, and being nu[mbered]

4

dated Thursday, May 20, 2021

of the 177 volume of said newspaper.

[signature] Pub[lisher]

Sworn to and subscribed before me this 20th

of May, 2021

[signature], Notary Public

Commission Expires [illegible]

Woodvill , MS 39669 • Phone: 601-888-4293 • Email: wrepublican@bellsouth.net